

# Control Valve

# Pilot Valve

# Model PRP





Flomatic Corporation

Sizes 3/8" / 10 mm

Pressure Reducing Pilot Valve

## Materials (Federalloy)



PILOT TYPE			
PSI RANGE	FACTORY SET @ PSI	SPRING NUMBER	ASSEMBLY NUMBER
5-80	30	9600397A	152100A
25-175	60	9600397B	152100B
2-35	15	9676000	152100C
30-300	60	9600397D	152100D

**Water System Valves sold in California 61<5**

The above marking certifies that this valve product has been tested by NSF International, an ANSI, accredited certifying laboratory, in accordance to Standard 61 and has achieved a normalized concentration under static conditions, within the meaning of Standard 61, of five (5) or fewer parts per billion of lead.

Danfoss Flomatic Corporation  
Glens Falls, NY  
[www.danfossflomatic.com](http://www.danfossflomatic.com)

Item #	Qty	Description	Material	Item #	Qty	Description	Material
1	1	Adjustment Cap	ABS	10	1	Diaphragm	Buna-n/Nylon
2	1	Adjusting Screw	Stainless Steel 18-8	11	1	Body Plug	Brass C36000
3	1	Jam Nut	Stainless Steel 18-8	12	1	O-Ring	Buna-n
4	8	Fillister Head Slotted Screw	Stainless Steel 18-8	13	1	3/8" Plug (not shown) Optional	Brass
5	1	Cover	Unleaded Bronze C89833	14	1	Disc Retainer	Bronze C31400
6	1	Spring Button	Stainless Steel 304	15	1	Yoke	Unleaded Bronze C89833
7	1	Spring	Steel	16	1	Body	Unleaded Bronze C89833
8	1	Nut	Galvanized Steel	17	1	Seat	Stainless Steel 304
9	1	Diaphragm Plate	Stainless Steel 316	18	1	Disc	Buna-n

Flomatic Corporation can accept no responsibility for possible errors in catalogues, brochures and other printed material. Flomatic Corporation reserves the right to alter its products without notices. This also applies to product already agreed. All trademarks in this material are property of the respective companies. All right reserved. ©2011 Flomatic Corporation. The drawings & information on this drawing sheet are the sole & exclusive property of Flomatic Corporation. Any reproduction, distribution, display or use of these drawings or information in whole or in part without written authorization of Flomatic Corporation is strictly prohibited.



July 9, 2003  
Dwg No: S152100 Rev: C (6/11)

FLOMATIC CORPORATION  
GLENS FALLS, N.Y. 12801  
PHONE (518) 761-9797  
FAX (518) 761-9798